



Comfortably CA

2026 Qualifying Product List for CONTRACTORS

Equipment eligibility criteria and incentives shown are applicable to sales from January 1, 2026 forward

AHRI Field Eligibility Requirements:

Model Status	Active	Production Stopped	Discontinued
--------------	--------	--------------------	--------------

Commercial Measures

Commercial Air-Cooled Air Conditioners Under 65k Btu/h

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Air-Cooled Air Conditioners Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

*Equipment with cooling capacities over 760,000 Btu/h will need to be submitted to program team for engineering review prior to distributor sales.

Building Type
All Commercial Building Types

Measure Restrictions
Not eligible for New Construction BOTH minimum IEER and EER need to be met to qualify

Packaged Systems:	EER	AND	IEER
Cooling Capacity (Btu/h) ≥ 65,000 & < 135,000			
Tier 1	≥ 11.5	AND	≥ 14.6
Tier 2	≥ 12	AND	≥ 14.6
Tier 3	≥ 12.5	AND	≥ 14.6
Tier 4	≥ 13.0	AND	≥ 15.0
Cooling Capacity (Btu/h) ≥ 135,000 & < 240,000			
Tier 1	≥ 11.5	AND	≥ 14.0
Tier 2	≥ 12	AND	≥ 14.0
Tier 3	≥ 12.5	AND	≥ 14.0
Cooling Capacity (Btu/h) ≥ 240,000 & < 760,000			
Tier 1	≥ 10.8	AND	≥ 13.0
Tier 2	≥ 11.5	AND	≥ 13.0
Tier 3	≥ 12.5	AND	≥ 15.5
Cooling Capacity (Btu/h) ≥ 760,000			
Tier 1	≥ 10.2	AND	≥ 12.3
Tier 2	≥ 11.0	AND	≥ 12.3
Tier 3	≥ 12.0	AND	≥ 13.8

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	SP-A (Single-Package Air-Conditioner, Air-Cooled)
	SPY-A (Year-Round Single-Package Air-Conditioner, Air-Cooled)

Measures Covered by above Tiers:

Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 1 2026
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 2 2026
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 3 2026
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 4 2026
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 1 2026
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 2 2026
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 3 2026
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 1 2026
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 2 2026
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 3 2026
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 1 2026
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 2 2026
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 3 2026

Commercial Air-Cooled Heat Pumps Under 65k Btu/h

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Air-Cooled Heat Pumps Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

Building Type
All Commercial Building Types

Packaged Systems:	EER	IEER	COP
Cooling Capacity (Btu/h) ≥ 65,000 & ≤ 134,000			
Tier 1	≥ 11.5	≥ 13.9	≥ 3.50
Tier 2	≥ 12.0	≥ 13.9	≥ 3.55
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000			
Tier 1	≥ 10.8	≥ 13.3	≥ 3.48
Tier 2	≥ 11.2	≥ 13.3	≥ 3.51
Cooling Capacity (Btu/h) ≥ 240,000 & ≤ 759,000			
Tier 1	≥ 9.7	≥ 12.3	≥ 3.30
Tier 2	≥ 10.0	≥ 12.3	≥ 3.30

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)

Measures Covered by above Tiers:

Pkg Heat Pump 65-134 k Btu/h Commercial Tier 1 2026
Pkg Heat Pump 65-134 k Btu/h Commercial Tier 2 2026
Pkg Heat Pump 135 -239 k Btu/h Commercial Tier 1 2026
Pkg Heat Pump 135 -239 k Btu/h Commercial Tier 2 2026
Pkg Heat Pump 240-759 k Btu/h Commercial Tier 1 2026
Pkg Heat Pump 240-759 k Btu/h Commercial Tier 2 2026

Commercial Multi-Capacity Unitary Air-Cooled Air Conditioners 65-240k Btu/h

AHRI List (web link): [Contact Program](#)

Building Type
All Commercial Building Types

	IEER		EER
Cooling Capacity (Btu/h) ≥ 65,000 & < 135,000			
Tier 1	≥ 19.0	AND	≥ 12.0
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000			
Tier 1	≥ 17.5	AND	≥ 12.0

Measure Restrictions
Not eligible for New Construction
BOTH minimum IEER and EER need to be met to qualify

The AC equipment must include advanced compressor capacity control (either a variable speed compressor, tandem compressor on a single refrigeration circuit, or multiple-step compressors).

The AC equipment must include a multi-speed (three steps or greater) indoor fan.

The AC equipment must include a gas-furnace heating section (no requirements on thermal efficiency).

Measures Covered by above Tiers:

Multi-Capacity Unitary Air-Cooled Commercial Air Conditioners 65-134 k Btu/h 2026
Multi-Capacity Unitary Air-Cooled Commercial Air Conditioners 135-239 k Btu/h 2026

Commercial Heat Pump Air Conditioner, Fuel Substitution Under 65k Btu/h

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Heat Pump Air Conditioner, Fuel Substitution Over 65k Btu/h

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Hot Water Boiler - Space Heating Only

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Steam Boiler - Space Heating Only

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Commercial Packaged Air Conditioner Heat Recovery

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Residential Measures

Residential High Efficiency Furnace with Variable Speed Motor

AHRI List (web link): [Residential Furnaces](#)

	AFUE (%)
Tier 1	≥ 92.0

Building Type
Single Family
Multi-Family
Mobile Home

Additional Eligibility Requirements based on AHRI Certified Product List:

Input Rating	≤ 225 kBtuh
Electronically Commutated Motor	Yes
Furnace Type	Weatherized; Non-weatherized
Fuel Type	*Natural Gas

*Furnaces listed as "Natural Gas, Propane" must be installed with natural gas to be eligible.

Measure Restrictions

Not eligible for New Construction
Equipment must be for use with Natural Gas ONLY
One measure per residential household

Measures Covered by above Tiers:

Residential High Efficiency Furnace with Variable Speed Motor Tier 1 2026

Residential Wall Furnace

****THIS MEASURE NOT CURRENTLY AVAILABLE****

Updates will be provided once the CPUC measure papers are available.

Residential Heat Pump HVAC, Fuel Substitution

AHRI List (web link): [Heat Pumps and Heat Pump Coils](#)

Split/Package Systems: SEER2 Rated Equipment			
	SEER2	AND	HSPF2
Tier 1, SEER2	≥ 15.2		≥ 7.7

Residential Building Type
Single Family
Multi-Family
Mobile Home

Measure Restrictions

Not eligible for New Construction
Customer must receive Electric service from an IOU
Propane customers are not eligible
BOTH minimum SEER2 and HSPF2 need to be met to qualify
Mini-Splits are not eligible
Must replace existing AC and Furnace
Natural Gas line to previously existing furnace must be capped

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)
	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan -Air Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

Measures Covered by above Tiers:

Residential Split System Heat Pump FuelSub Tier 1 2026
--

Please note: Any incentive amounts or product types included in this and other supporting documents are intended as references only and are not meant to replace the PPC. The PPC will always have the most current incentive amount and qualifying products. Incentive levels can and will change throughout the life of the program based upon market trends, program performance, or utility needs and priorities. Please contact the program if you are uncertain of a product's eligibility or incentive level. You can contact the program by reaching out to your Account Manager, by emailing info@comfortablyca.com, or by calling 855-700-4651.

The Comfortably California program and this message are funded by California utility customers under the auspices of the California Public Utilities Commission and are implemented by CLEAResult under a contract awarded by San Diego Gas & Electric® Company (SDG&E®). Program funds are available on a first-come, first-served basis until exhausted. This program may be modified or terminated without prior notice. Customers who choose to participate are not obligated to purchase any additional services offered by CLEAResult or any other third party. Eligibility requirements and terms and conditions apply; see the program conditions for details. Actual savings may vary. The trademarks used herein are the property of their respective owners.