



Comfortably CA

2022 Qualifying Product List

See the Measure Rules Handbook for a complete list of eligibility requirements. The most current version can be found on the Program Partner Central (PPC) online web portal in the Resources section.

AHRI Field Eligibility Requirements:

Model Status	Active	Production Stopped	Discontinued
--------------	--------	--------------------	--------------

Commercial Measures

Commercial Air-Cooled Air Conditioners Under 65k Btu/h

AHRI List (web link):	Air Conditioners and Air Conditioner Coils
-----------------------	--

Building Type	All Commercial Building Types
---------------	-------------------------------

Packaged Systems:	SEER		EER
Cooling Capacity (Btu/h) < 55,000			
Tier 1	≥15 & <16	OR	≥12 & <12.4
Tier 2	≥16 & <17	OR	≥12.4 & <13
Tier 3	≥17 & <18	OR	≥13 & <14
Tier 4	≥18	OR	≥14
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000			
Tier 1	≥15 & <16	OR	≥12 & <12.4
Tier 2	≥16 & <17	OR	≥12.4 & <13
Tier 3	≥17 & <18	OR	≥13 & <14
Tier 4	≥18	OR	≥14

*EITHER minimum SEER or EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	SP-A (Single-Package Air-Conditioner, Air-Cooled)
	SPY-A (Year-Round Single-Package Air-Conditioner, Air-Cooled)

Measures Covered by above Tiers:
Pkg Air-Cooled Air Conditioner <55k Btu/h Commercial no economizer Tier 1 2022
Pkg Air-Cooled Air Conditioner <55k Btu/h Commercial no economizer Tier 2 2022
Pkg Air-Cooled Air Conditioner <55k Btu/h Commercial no economizer Tier 3 2022
Pkg Air-Cooled Air Conditioner <55k Btu/h Commercial no economizer Tier 4 2022
Pkg Air-Cooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 1 2022
Pkg Air-Cooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 2 2022
Pkg Air-Cooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 3 2022
Pkg Air-Cooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 4 2022

Split Systems:	SEER		EER
Cooling Capacity (Btu/h) < 45,000			
Tier 1	≥15 & <16	OR	≥12.5 & <13

Tier 2	≥16 & <17	OR	≥13 & <13.5
Tier 3	≥17 & <18	OR	≥13.5 & <14
Tier 4	≥18	OR	≥14
Cooling Capacity (Btu/h) ≥ 45,000 & < 55,000			
Tier 1	≥15 & <16	OR	≥12.5 & <13
Tier 2	≥16 & <17	OR	≥13 & <13.5
Tier 3	≥17 & <18	OR	≥13.5 & <14
Tier 4	≥18	OR	≥14
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000			
Tier 1	≥15 & <16	OR	≥12.5 & <13
Tier 2	≥16 & <17	OR	≥13 & <13.5
Tier 3	≥17 & <18	OR	≥13.5 & <14
Tier 4	≥18	OR	≥14

*EITHER minimum SEER or EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	RCU-A-C (Split System: Air-Cooled Condensing Unit, Coil Alone)
	RCU-A-CB (Split System: Air-Cooled Condensing Unit, Coil with Blower)
	RCU-A-CB-O (Split System: Air-Cooled Condensing Unit, Coil with Blower, (Free Delivery))

Measures Covered by above Tiers:

Split Air-Cooled Air Conditioner <45k Btu/h Commercial no economizer Tier 1 2022
Split Air-Cooled Air Conditioner <45k Btu/h Commercial no economizer Tier 2 2022
Split Air-Cooled Air Conditioner <45k Btu/h Commercial no economizer Tier 3 2022
Split Air-Cooled Air Conditioner <45k Btu/h Commercial no economizer Tier 4 2022
Split AirCooled Air Conditioner 45-55k Btu/h Commercial no economizer Tier 1 2022
Split AirCooled Air Conditioner 45-55k Btu/h Commercial no economizer Tier 2 2022
Split AirCooled Air Conditioner 45-55k Btu/h Commercial no economizer Tier 3 2022
Split AirCooled Air Conditioner 45-55k Btu/h Commercial no economizer Tier 4 2022
Split AirCooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 1 2022
Split AirCooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 2 2022
Split AirCooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 3 2022
Split AirCooled Air Conditioner 55-65k Btu/h Commercial no economizer Tier 4 2022

Commercial Air-Cooled Air Conditioners Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

Building Type

*Equipment with cooling capacities over 760,000 Btu/h will need to be submitted to program team for engineering review prior to distributor sales.

All Commercial Building Types

Split Systems:	
	EER
Cooling Capacity (Btu/h) ≥ 65,000 & ≤ 134,000	
Tier 1	≥11.5 & <12
Tier 2	≥12 & <12.5
Tier 3	≥12.5 & <13
Tier 4	≥13.0
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000	
Tier 1	≥11.5 & <12
Tier 2	≥12 & <12.5
Tier 3	≥12.5
Cooling Capacity (Btu/h) ≥ 240,000 & ≤ 759,000	
Tier 1	≥10.8 & <11.5
Tier 2	≥11.5 & <12.5

Tier 3	≥12.5
Cooling Capacity (Btu/h) ≥ 760,000	
Tier 1	≥10.2 & <11
Tier 2	≥11.0 & <12
Tier 3	≥12.0

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	SP-A (Single-Package Air-Conditioner, Air-Cooled)
	SPY-A (Year-Round Single-Package Air-Conditioner, Air-Cooled)

Measures Covered by above Tiers:

Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 1 2022
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 2 2022
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 3 2022
Pkg Air-Cooled Air Conditioner 65-134 k Btu/h Commercial Tier 4 2022
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 1 2022
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 2 2022
Pkg Air-Cooled Air Conditioner 135-239 k Btu/h Commercial Tier 3 2022
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 1 2022
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 2 2022
Pkg Air-Cooled Air Conditioner 240-759 k Btu/h Commercial Tier 3 2022
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 1 2022
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 2 2022
Pkg Air-Cooled Air Conditioner Over 760 k Btu/h Commercial Tier 3 2022

Commercial Air-Cooled Heat Pumps Under 65k Btu/h

AHRI List (web link): [Heat Pumps and Heat Pump Coils](#)

Building Type
All Commercial Building Types

Packaged Systems:	SEER		EER
Cooling Capacity (Btu/h) < 55,000			
Tier 1	≥15 & <16	OR	≥12 & <12.4
Tier 2	≥16 & <17	OR	≥12.4 & <13
Tier 3	≥17 & <18	OR	≥13 & <14
Tier 4	≥18	OR	≥14
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000			
Tier 1	≥15 & <16	OR	≥12 & <12.4
Tier 2	≥16 & <17	OR	≥12.4 & <13
Tier 3	≥17 & <18	OR	≥13 & <14
Tier 4	≥18	OR	≥14

*EITHER minimum SEER or EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)
-----------	---

Measures Covered by above Tiers:

Pkg Heat Pump <55k Btu/h Commercial no economizer Tier 1 2022
Pkg Heat Pump <55k Btu/h Commercial no economizer Tier 2 2022
Pkg Heat Pump <55k Btu/h Commercial no economizer Tier 3 2022
Pkg Heat Pump <55k Btu/h Commercial no economizer Tier 4 2022
Pkg Heat Pump 55-65k Btu/h Commercial no economizer Tier 1 2022
Pkg Heat Pump 55-65k Btu/h Commercial no economizer Tier 2 2022

Pkg Heat Pump 55-65k Btu/h Commercial no economizer Tier 3 2022
Pkg Heat Pump 55-65k Btu/h Commercial no economizer Tier 4 2022

Split Systems:	SEER		EER	
Cooling Capacity (Btu/h) < 55,000				
Tier 1	≥15 & <16	OR	≥12.5 & <13	
Tier 2	≥16 & <17	OR	≥13 & <13.5	
Tier 3	≥17 & <18	OR	≥13.5 & <14	
Tier 4	≥18	OR	≥14	
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000				
Tier 1	≥15 & <16	OR	≥12.5 & <13	
Tier 2	≥16 & <17	OR	≥13 & <13.5	
Tier 3	≥17 & <18	OR	≥13.5 & <14	
Tier 4	≥18	OR	≥14	

*EITHER minimum SEER or EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan --Air Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

Measures Covered by above Tiers:
Split Heat Pump <55k Btu/h Commercial no economizer Tier 1 2022
Split Heat Pump <55k Btu/h Commercial no economizer Tier 2 2022
Split Heat Pump <55k Btu/h Commercial no economizer Tier 3 2022
Split Heat Pump <55k Btu/h Commercial no economizer Tier 4 2022
Split Heat Pump 55-65k Btu/h Commercial no economizer Tier 1 2022
Split Heat Pump 55-65k Btu/h Commercial no economizer Tier 2 2022
Split Heat Pump 55-65k Btu/h Commercial no economizer Tier 3 2022
Split Heat Pump 55-65k Btu/h Commercial no economizer Tier 4 2022

Commercial Air-Cooled Heat Pumps Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

Building Type
All Commercial Building Types

Packaged Systems:	EER
Cooling Capacity (Btu/h) ≥ 65,000 & ≤ 134,000	
Tier 1	≥11.5 & <12
Tier 2	≥12
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000	
Tier 1	≥11.5 & <12
Tier 2	≥12
Cooling Capacity (Btu/h) ≥ 240,000 & ≤ 759,000	
Tier 1	≥10.5 & <10.8
Tier 2	≥10.8

Measures Covered by above Tiers:
Pkg Heat Pump 65-134 k Btu/h Commercial Tier 1 2022
Pkg Heat Pump 65-134 k Btu/h Commercial Tier 2 2022
Pkg Heat Pump 135 -239 k Btu/h Commercial Tier 1 2022
Pkg Heat Pump 135 -239 k Btu/h Commercial Tier 2 2022

Pkg Heat Pump 240-759 k Btu/h Commercial Tier 1 2022

Pkg Heat Pump 240-759 k Btu/h Commercial Tier 2 2022

Commercial Multi-Capacity Unitary Air-Cooled Air Conditioners 65-240k Btu/h

AHRI List (web link):

Contact Program

Building Type

All Commercial Building Types

	IEER		EER
Cooling Capacity (Btu/h) ≥ 65,000 & ≤ 134,000			
Tier 1	≥19.0	AND	≥12.0
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000			
Tier 1	≥17.5	AND	≥12.0

*BOTH minimum IEER and EER need to be met to qualify

The AC equipment must include advanced compressor capacity control (either a variable speed compressor, tandem compressor on a single refrigeration circuit, or multiple-step compressors).

The AC equipment must include a multi-speed (three steps or greater) indoor fan.

The AC equipment must include a gas-furnace heating section (no requirements on thermal efficiency).

Measures Covered by above Tiers:

Multi-Capacity Unitary Air-Cooled Commercial Air Conditioners 65-134 k Btu/h 2022

Multi-Capacity Unitary Air-Cooled Commercial Air Conditioners 135-239 k Btu/h 2022

Commercial Heat Pump Air Conditioner, Fuel Substitution Under 65k Btu/h

AHRI List (web link):

Heat Pumps and Heat Pump Coils

Building Type

All Commercial Building Types

Packaged Systems:

	SEER		HSPF
Cooling Capacity (Btu/h) < 65,000 - Single or High Stage (95F),btuh			
1 Stage & 2 Stage	≥15.0 & <16	AND	≥ 8.2 & < 8.5
*Indoor Cooling Minimum Air Volume Rate (BI SCFM) - Has value			
Tier 1	≥16	AND	≥ 8.5
Tier 2	≥17	AND	≥ 9.0

*BOTH minimum HSPF and SEER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type

HSP-A (Single-Package Heat Pump Air-Source) *only available under 65k Btu

Measures Covered by above Tiers:

Commercial Packaged Heat Pump FuelSub <65k Btu/h 1 stage 2022

Commercial Packaged Heat Pump FuelSub <65k Btu/h 2 stage 2022

Commercial Packaged Heat Pump FuelSub <65k Btu/h Tier 1 2022

Commercial Packaged Heat Pump FuelSub <65k Btu/h Tier 2 2022

Split Systems:

	SEER		HSPF
Cooling Capacity (Btu/h) < 65,000 - Single or High Stage (95F),btuh			
Tier 1	≥15	AND	≥ 8.7
Tier 2	≥16	AND	≥ 9
Tier 3	≥17	AND	≥ 9.4
Tier 4	≥18	AND	≥ 9.7

*BOTH minimum HSPF and SEER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan --Air Source)
	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

Measures Covered by above Tiers:

Commercial Split Heat Pump FuelSub <65k Btu/h Tier 1 2022
Commercial Split Heat Pump FuelSub <65k Btu/h Tier 2 2022
Commercial Split Heat Pump FuelSub <65k Btu/h Tier 3 2022
Commercial Split Heat Pump FuelSub <65k Btu/h Tier 4 2022

Commercial Heat Pump Air Conditioner, Fuel Substitution Over 65k Btu/h

AHRI List (web link):	Unitary Large Equipment
-----------------------	-------------------------

Building Type
All Commercial Building Types

Packaged Systems:

	COP		IEER
Cooling Capacity (Btu/h) ≥ 65,000 & ≤ 134,000			
Tier 1	≥ 3.4	AND	≥ 14.1
Tier 2	≥ 3.4	AND	≥ 14.8
Cooling Capacity (Btu/h) ≥ 135,000 & ≤ 239,000			
Tier 1	≥ 3.2	AND	≥ 14.4
Tier 2	≥ 3.2	AND	≥ 15.4
Cooling Capacity (Btu/h) ≥ 240,000 & ≤ 759,000			
Tier 1	≥ 3.2	AND	≥ 12.3
Tier 2	≥ 3.2	AND	≥ 12.8

*BOTH minimum COP and EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)
-----------	---

Measures Covered by above Tiers:

Commercial Packaged Heat Pump FuelSub 65-134 k Btu/h Tier 1 2022
Commercial Packaged Heat Pump FuelSub 65-134 k Btu/h Tier 2 2022
Commercial Packaged Heat Pump FuelSub 135-239 k Btu/h Tier 1 2022
Commercial Packaged Heat Pump FuelSub 135-239 k Btu/h Tier 2 2022
Commercial Packaged Heat Pump FuelSub 240-759 k Btu/h Tier 1 2022
Commercial Packaged Heat Pump FuelSub 240-759 k Btu/h Tier 2 2022

Commercial Hot Water Boiler - Space Heating Only

AHRI List (web link):	Commercial Boilers
-----------------------	--------------------

Building Type
Education - Community College
Education - Secondary School
Education - University
Health/Medical - Hospital
Lodging - Hotel
Health/Medical - Nursing Home
Office - Large, Small
Retail - Multistory Large

	Thermal Efficiency
Input Rating, MBH ≥ 300 & ≤ 2,500	
Tier 1A	≥ 85.0 & < 94.0
Tier 2	≥ 94.0
Tier 3	≥ 94.0
Input Rating, MBH > 2,500	
Tier 1B	≥ 83.0 & < 94.0
Tier 2	≥ 94.0
Tier 3	≥ 94.0

*For products that qualify for both Tier 2 and Tier 3, incentives will be based on the OA temperature

Additional Eligibility Requirements based on AHRI Certified Product List:

Heating Medium	Water; Steam
Fuel Type	Natural Gas; Propane Gas

Measures Covered by above Tiers:

Commercial Hot Water Boiler Tier 1A 140-165 OA Reset Space Heating Only 2022
Commercial Hot Water Boiler Tier 1B 140-165 OA Reset Space Heating Only 2022
Commercial Hot Water Boiler Tier 2 140-165 OA Reset Space Heating Only 2022
Commercial Hot Water Boiler Tier 3 115-140 OA Reset Space Heating Only 2022

Commercial Steam Boiler - Space Heating Only

AHRI List (web link): [Commercial Boilers](#)

	Thermal Efficiency
Input Rating, MBH: ≥ 300 & $\leq 2,500$	
Tier 1	≥ 82.0
Input Rating, MBH: $\geq 2,500$	
Tier 1	≥ 82.0
Tier 2	≥ 80.0 & < 82.0

*Boilers listed as Water, Steam must be installed as steam boilers to be eligible

Building Type
Education - Community College
Education - Secondary School
Education - University
Health/Medical - Hospital
Lodging - Hotel
Health/Medical - Nursing Home
Office - Large, Small
Retail - Multistory Large

Additional Eligibility Requirements based on AHRI Certified Product List:

Heating Medium	Water; Steam*
Fuel Type	Natural Gas; Propane Gas

Measures Covered by above Tiers:

Commercial Steam Boiler Tier 1 140-165 OA Reset Space Heating Only 2022
Commercial Steam Boiler Tier 2 140-165 OA Reset Space Heating Only 2022

Commercial Air-Cooled Constant Speed Screw Chiller

AHRI List (web link): [Contact Program](#)

Building Type
All Commercial Building Types

	IPLV		EER
Cooling Capacity (Btu/h) < 150			
Tier 1	≥ 15.1	AND	≥ 11.1
Tier 2	≥ 16.6	AND	≥ 12.1
Cooling Capacity (Btu/h) ≥ 150			
Tier 1	≥ 15.4	AND	≥ 11.1
Tier 2	≥ 16.9	AND	≥ 12.1

*BOTH minimum IPLV and EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	Screw
-----------	-------

Measures Covered by above Tiers:

Commercial Air-Cooled Constant Speed Screw Chiller Tier 1 2022
Commercial Air-Cooled Constant Speed Screw Chiller Tier 2 2022

Commercial Air-Cooled Variable Speed Screw Chiller, Path B

AHRI List (web link):	Contact Program
-----------------------	-----------------

Building Type
All Commercial Building Types

	IPLV		EER
Cooling Capacity (Btu/h) <150			
Tier 1A	≥17.7	AND	≥10.4
Tier 2	≥19	AND	≥10.4
Cooling Capacity (Btu/h) ≥150			
Tier 1B	≥19	AND	≥10.4
Tier 2	≥19.3	AND	≥10.4

*BOTH minimum IPLV and EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	Screw

Measures Covered by above Tiers:	
Commercial Air-Cooled Constant Speed Screw Chiller Tier 1A Path B 2022	
Commercial Air-Cooled Constant Speed Screw Chiller Tier 1B Path B 2022	
Commercial Air-Cooled Constant Speed Screw Chiller Tier 2 Path B 2022	

Commercial Packaged Air Conditioner Heat Recovery

AHRI List (web link):	Contact Program
-----------------------	-----------------

Building Type
Restaurant - Fast-Food

Eligibility Requirements:	
Equipment Type	Packaged AC with air-to-water heat recovery used to heat incoming service hot water

Measure Covered by above Measure:	
Packaged Air Conditioner Heat Recovery Commercial 2022	

Commercial Software Controlled Switch Reluctance Motor

AHRI List (web link):	Contact Program
-----------------------	-----------------

Building Type
All Commercial Building Types

Eligibility Requirements:	
Equipment Type	Furnace Blower Motor Horsepower
Software-Controlled Switch Reluctance Motor	≥1.0 & ≤3.0

This measure must replace the existing 1 to 3 hp supply fan motor in a packaged HVAC system. The new motor and controls must be UL Listed. The installation of this measure shall meet all applicable regulations, including but not limited to the current California Building Energy Efficiency Standards (Title 24), federal code, and the National Electrical Code® (NEC). This measure is not eligible for supply fan motors rated ≥1 hp and ≥3 hp (nominal). This measure is not eligible for other fans, such as the return fan or outdoor air fan of a packaged HVAC unit.

Measure Covered by above Measure:	
Packaged Air Conditioner Heat Recovery Commercial 2022	

Classroom HVAC Occupancy Sensor

AHRI List (web link):	Contact Program
-----------------------	-----------------

Building Type
Education - Primary School
Education - Secondary School
Education - Relocatable Classroom

Eligibility Requirements:	
Equipment Type	Classroom HVAC occupancy sensor DX furnace, EPr and Ese
	Classroom HVAC occupancy sensor heat pump, ERC

The measure requires installation of an HVAC occupancy sensing thermostat in the classroom. This control equipment includes, but is not limited to: An occupancy sensing thermostat, An occupancy sensor (wired or wireless), Wiring (if wired), Signal receiver and power pack (if wireless). The measure is only applicable for classrooms in education primary schools (EPr), and education secondary schools (ESe). This measure is not applicable for education community colleges, and education universities, unless these buildings have relocatable classrooms with packaged HVAC units. This measure is applicable to all vintages.

Measure Covered by above Measure:
Classroom HVAC occupancy sensor DX furnace EPr and ESe 2022
Classroom HVAC occupancy sensor heat pump ERC 2022

Residential Measures

Residential High Efficiency Furnace with Variable Speed Motor

AHRI List (web link):	Residential Furnaces
-----------------------	----------------------

Building Type
Single Family
Multi-Family
Mobile Home

	AFUE (%)
Tier 1	≥ 92.0 & < 95.0
Tier 2	≥ 95.0 & < 97.0
Tier 3	≥ 97.0

Additional Eligibility Requirements based on AHRI Certified Product List:	
Input Rating	≤ 225 Mbtuh
Electronically Commutated Motor	Yes
Furnace Type	Weatherized; Non-weatherized
Fuel Type	Natural Gas; Natural Gas, Propane Gas*

*All equipment must be for use with Natural Gas ONLY. One incentive per household.

Measures Covered by above Tiers:
Residential High Efficiency Furnace with Variable Speed Motor Tier 1 2022
Residential High Efficiency Furnace with Variable Speed Motor Tier 2 2022
Residential High Efficiency Furnace with Variable Speed Motor Tier 3 2022

Residential Gravity Wall Furnace

AHRI List (web link):	Direct Heating Equipment
-----------------------	--------------------------

Residential Building Type
Single Family
Multi-Family

Heating Type	AFUE (%)
Input Rating (Btu/h) ≥ 25,000 & < 35,000	

	Gravity	≥ 70.0
Input Rating (Btu/h) ≥ 35,000 & < 60,000		
	Gravity	≥ 70.0
Input Rating (Btu/h) ≥ 25,000 & < 42,000		
	Fan	≥ 82.0

*Not eligible for New Construction

Additional Eligibility Requirements based on AHRI Certified Product List:	
Fuel Type	Natural Gas: Natural Gas, Propane Gas
Equipment Type	Wall Furnace

Measures Covered by above Measure:	
Gravity wall furnace residential 25000 Btuh 70 AFUE 2022	
Gravity wall furnace residential 35000 Btuh 70 AFUE 2022	
Gravity wall furnace residential 50000 Btuh 70 AFUE 2022	
Fan wall furnace residential 30000 Btuh 82 AFUE 2022	

Residential Heat Pump HVAC, Fuel Substitution

AHRI List (web link):	Heat Pumps and Heat Pump Coils
-----------------------	--

Residential Building Type
Single Family
Multi-Family
Mobile Home

Split Systems:			
	SEER	AND	HSPF
Tier 1	≥15	AND	≥ 8.7
Tier 2	≥16	AND	≥ 9
Tier 3	≥17	AND	≥ 9.4
Tier 4	≥18	AND	≥ 9.7

*BOTH minimum SEER and HSPF need to be met to qualify

*Not eligible for New Construction

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan --Air Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

Measures Covered by above Tiers:	
Residential Split System Heat Pump FuelSub Tier 1 2022	
Residential Split System Heat Pump FuelSub Tier 2 2022	
Residential Split System Heat Pump FuelSub Tier 3 2022	
Residential Split System Heat Pump FuelSub Tier 4 2022	

Please note: Any incentive amounts or product types included in this and other supporting documents are intended as references only. Incentive levels can and will change throughout the life of the program based upon market trends, program performance, or utility needs and priorities. Please contact the program if you are uncertain of a product's eligibility or incentive level. You can contact the program by emailing info@comfortablyca.com, or by calling 855-700-4651.