



Comfortably CA

## 2023 Qualifying Product List

See the Measure Rules Handbook for a complete list of eligibility requirements. The most current version can be found on the Program Partner Central (PPC) online web portal in the Resources section.

### AHRI Field Eligibility Requirements:

Model Status	Active	Production Stopped	Discontinued
--------------	--------	--------------------	--------------

## Commercial Measures

### Commercial Air-Cooled Air Conditioners Under 65k Btu/h

AHRI List (web link):	<a href="#">Air Conditioners and Air Conditioner Coils</a>	Building Type	All Commercial Building Types
-----------------------	--	---------------	-------------------------------

Packaged Systems:	
	SEER
Cooling Capacity (Btu/h) < 55,000	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	SP-A (Single-Package Air-Conditioner, Air-Cooled)
	SPY-A (Year-Round Single-Package Air-Conditioner, Air-Cooled)

Split Systems:	
	SEER
Cooling Capacity (Btu/h) < 45,000	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18
Cooling Capacity (Btu/h) ≥ 45,000 & < 55,000	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18
Cooling Capacity (Btu/h) ≥ 55,000 & < 65,000	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	RCU-A-C (Split System: Air-Cooled Condensing Unit, Coil Alone)
	RCU-A-CB (Split System: Air-Cooled Condensing Unit, Coil with Blower)
	RCU-A-CB-O (Split System: Air-Cooled Condensing Unit, Coil with Blower, (Free Delivery))

# Commercial Air-Cooled Air Conditioners Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

Building Type  
All Commercial Building Types

\*Equipment with cooling capacities over 760,000 Btu/h will need to be submitted to program team for engineering review prior to distributor sales.

Split Systems:			
	EER		IEER
<b>Cooling Capacity (Btu/h) ≥ 65,000 &amp; ≤ 134,000</b>			
Tier 1	≥11.5	AND	≥14.6
Tier 2	≥12	AND	≥14.6
Tier 3	≥12.5	AND	≥14.6
Tier 4	≥13.0	AND	≥15.0
<b>Cooling Capacity (Btu/h) ≥ 135,000 &amp; ≤ 239,000</b>			
Tier 1	≥11.5	AND	≥14.0
Tier 2	≥12	AND	≥14.0
Tier 3	≥12.5	AND	≥14.0
<b>Cooling Capacity (Btu/h) ≥ 240,000 &amp; ≤ 759,000</b>			
Tier 1	≥10.8	AND	≥13.0
Tier 2	≥11.5	AND	≥13.0
Tier 3	≥12.5	AND	≥15.5
<b>Cooling Capacity (Btu/h) ≥ 760,000</b>			
Tier 1	≥10.2	AND	≥12.3
Tier 2	≥11.0	AND	≥12.3
Tier 3	≥12.0	AND	≥13.8

\*BOTH minimum IEER and EER need to be met to qualify

Additional Eligibility Requirements based on AHRI Certified Product List:	
AHRI Type	SP-A (Single-Package Air-Conditioner, Air-Cooled)
	SPY-A (Year-Round Single-Package Air-Conditioner, Air-Cooled)

# Commercial Air-Cooled Heat Pumps Under 65k Btu/h

AHRI List (web link): [Heat Pumps and Heat Pump Coils](#)

**Building Type**  
All Commercial Building Types

Packaged Systems:	
	SEER
<b>Cooling Capacity (Btu/h) &lt; 55,000</b>	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18
<b>Cooling Capacity (Btu/h) ≥ 55,000 &amp; &lt; 65,000</b>	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18

**Additional Eligibility Requirements based on AHRI Certified Product List:**

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)
-----------	---

Split Systems:	
	SEER
<b>Cooling Capacity (Btu/h) &lt; 55,000</b>	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18
<b>Cooling Capacity (Btu/h) ≥ 55,000 &amp; &lt; 65,000</b>	
Tier 1	≥15 & <16
Tier 2	≥16 & <17
Tier 3	≥17 & <18
Tier 4	≥18

**Additional Eligibility Requirements based on AHRI Certified Product List:**

AHRI Type	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan --Air Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

## Commercial Air-Cooled Heat Pumps Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

**Building Type**  
All Commercial Building Types

Packaged Systems:	
	EER
<b>Cooling Capacity (Btu/h) ≥ 65,000 &amp; ≤ 134,000</b>	
Tier 1	≥11.5 & <12
Tier 2	≥12
<b>Cooling Capacity (Btu/h) ≥ 135,000 &amp; ≤ 239,000</b>	
Tier 1	≥11.5 & <12
Tier 2	≥12
<b>Cooling Capacity (Btu/h) ≥ 240,000 &amp; ≤ 759,000</b>	
Tier 1	≥10.5 & <10.8
Tier 2	≥10.8

**Additional Eligibility Requirements based on AHRI Certified Product List:**

AHRI Type	HSP-A (Single-Package Heat Pump Air-Source)
-----------	---

## Commercial Multi-Capacity Unitary Air-Cooled Air Conditioners 65-240k Btu/h

AHRI List (web link): [Contact Program](#)

**Building Type**  
All Commercial Building Types

	IEER	AND	EER
<b>Cooling Capacity (Btu/h) ≥ 65,000 &amp; ≤ 134,000</b>			
Tier 1	≥19.0	AND	≥12.0
<b>Cooling Capacity (Btu/h) ≥ 135,000 &amp; ≤ 239,000</b>			
Tier 1	≥17.5	AND	≥12.0

\*BOTH minimum IEER and EER need to be met to qualify

The AC equipment must include advanced compressor capacity control (either a variable speed compressor, tandem compressor on a single refrigeration circuit, or multiple-step compressors).

The AC equipment must include a multi-speed (three steps or greater) indoor fan.

The AC equipment must include a gas-furnace heating section (no requirements on thermal efficiency).

# Commercial Heat Pump Air Conditioner, Fuel Substitution Under 65k Btu/h

AHRI List (web link):

[Heat Pumps and Heat Pump Coils](#)

Building Type

All Commercial Building Types

## Packaged Systems:

	SEER		HSPF
Cooling Capacity (Btu/h) < 65,000 - Single or High Stage (95F),btuh			
1 Stage & 2 Stage	≥15.0 & <16	AND	≥ 8.2 & < 8.5
*Indoor Cooling Minimum Air Volume Rate (BI SCFM) - Has value			
Tier 1	≥16	AND	≥ 8.5
Tier 2	≥17	AND	≥ 9.0

\*BOTH minimum HSPF and SEER need to be met to qualify

\*Customer must receive Gas or Electric service from an IOU

## Split Systems:

	SEER		HSPF
Cooling Capacity (Btu/h) < 65,000 - Single or High Stage (95F),btuh			
Tier 1	≥15	AND	≥ 8.7
Tier 2	≥16	AND	≥ 9
Tier 3	≥17	AND	≥ 9.4
Tier 4	≥18	AND	≥ 9.7

\*BOTH minimum HSPF and SEER need to be met to qualify

\*Customer must receive Gas or Electric service from an IOU

## Additional Eligibility Requirements based on AHRI Certified Product List:

AHRI Type	
	HRCU-A-C (Split System: Heat Pump with Remote Outdoor Unit with No Indoor Fan --Air Source)
	HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)
	HRCU-A-CB-O (Split System: Heat Pump with Remote Outdoor Unit-Air-Source, Free Delivery)

## Commercial Heat Pump Air Conditioner, Fuel Substitution Over 65k Btu/h

AHRI List (web link): [Unitary Large Equipment](#)

Building Type
All Commercial Building Types

Packaged Systems:			
	COP		IEER
Cooling Capacity (Btu/h) $\geq 65,000$ & $\leq 134,000$			
Tier 2	$\geq 3.4$	AND	$\geq 16.0$
Cooling Capacity (Btu/h) $\geq 135,000$ & $\leq 239,000$			
Tier 2	$\geq 3.2$	AND	$\geq 15.5$
Cooling Capacity (Btu/h) $\geq 240,000$ & $\leq 759,000$			
Tier 2	$\geq 3.2$	AND	$\geq 14.0$

\*BOTH minimum COP and EER need to be met to qualify

## Commercial Hot Water Boiler - Space Heating Only

AHRI List (web link): [Commercial Boilers](#)

Building Type
Education - Community College
Education - Secondary School
Education - University
Health/Medical - Hospital
Lodging - Hotel
Health/Medical - Nursing Home
Office - Large, Small
Retail - Multistory Large

Thermal Efficiency	
Input Rating, MBH $\geq 300$ & $\leq 2,500$	
Tier 1A*	$\geq 85.0$
Tier 2*	$\geq 94.0$
Tier 3	$\geq 94.0$
Input Rating, MBH $> 2,500-10,000$	
Tier 1B*	$\geq 85.3$
Tier 2*	$\geq 93.0$
Tier 3**	$\geq 93.0$

\*For products that qualify for both Tier 2 and Tier 3, incentives will be based on the OA temperature

\*140°-165° OA Reset Temp

\*\*115°-140° OA Reset Temp

Maximum incentive \$10,000 per unit

Additional Eligibility Requirements based on AHRI Certified Product List:

Heating Medium	Water, Steam
Fuel Type	Natural Gas, Propane Gas

## Commercial Steam Boiler - Space Heating Only

AHRI List (web link): [Commercial Boilers](#)

Building Type
Education - Community College
Education - Secondary School
Education - University
Health/Medical - Hospital
Lodging - Hotel
Health/Medical - Nursing Home
Office - Large, Small
Retail - Multistory Large

Thermal Efficiency	
Input Rating, MBH: $\geq 300$ & $\leq 2,500$	
Tier 1	$\geq 82.0$
Input Rating, MBH: $\geq 2,500$	
Tier 1	$\geq 83.0$
Tier 2	$\geq 84.0$

Boilers listed as Water, Steam must be installed as steam boilers to be eligible

Maximum incentive \$10,000 per unit

Additional Eligibility Requirements based on AHRI Certified Product List:

Heating Medium	Water, Steam*
Fuel Type	Natural Gas, Propane Gas

## Commercial Air-Cooled Constant Speed Screw Chiller

AHRI List (web link): [Contact Program](#)

**Building Type**  
All Commercial Building Types

	IPLV		EER
<b>Cooling Capacity (tons) &lt;150</b>			
Tier 1	≥15.1	AND	≥11.1
Tier 2	≥16.4	AND	≥12.1
<b>Cooling Capacity (tons) ≥150</b>			
Tier 1	≥15.4	AND	≥11.1
Tier 2	≥16.8	AND	≥12.1

\*BOTH minimum IPLV and EER need to be met to qualify

\*Not available for New Construction

**Additional Eligibility Requirements based on AHRI Certified Product List:**

AHRI Type	Screw
-----------	-------

## Commercial Air-Cooled Variable Speed Screw Chiller, Path B

AHRI List (web link): [Contact Program](#)

**Building Type**  
All Commercial Building Types

	IPLV		EER
<b>Cooling Capacity (tons) &lt;150</b>			
Tier 1A	≥17.7	AND	≥10.4
Tier 2	≥19.3	AND	≥10.4
<b>Cooling Capacity (tons) ≥150</b>			
Tier 1B	≥18	AND	≥10.4
Tier 2	≥19.0	AND	≥10.4

\*BOTH minimum IPLV and EER need to be met to qualify

\*Not available for New Construction

**Additional Eligibility Requirements based on AHRI Certified Product List:**

AHRI Type	Screw
-----------	-------

## Commercial Packaged Air Conditioner Heat Recovery

AHRI List (web link): [Contact Program](#)

**Building Type**  
Restaurant - Fast-Food

**Eligibility Requirements:**

Equipment Type	Packaged AC with air-to-water heat recovery used to heat incoming service hot water
----------------	---

**Measure Covered by above Measure:**

Packaged Air Conditioner Heat Recovery Commercial 2022
--

## Commercial Software Controlled Switch Reluctance Motor

AHRI List (web link):

Contact Program

Building Type

All Commercial Building Types

### Eligibility Requirements:

Equipment Type	Furnace Blower Motor Horsepower
Software-Controlled Switch Reluctance Motor	$\geq 1.0$ & $\leq 3.0$

This measure must replace the existing 1 to 3 hp supply fan motor in a packaged HVAC system. The new motor and controls must be UL Listed. The installation of this measure shall meet all applicable regulations, including but not limited to the current California Building Energy Efficiency Standards (Title 24), federal code, and the National Electrical Code® (NEC). This measure is not eligible for supply fan motors rated  $\geq 1$  hp and  $\geq 3$  hp (nominal). This measure is not eligible for other fans, such as the return fan or outdoor air fan of a packaged HVAC unit.

## Classroom HVAC Occupancy Sensor

AHRI List (web link):

Contact Program

Building Type

Education - Primary School

Education - Secondary School

Education - Relocatable Classroom

### Eligibility Requirements:

Equipment Type	Classroom HVAC occupancy sensor DX furnace, EPr and ESe
	Classroom HVAC occupancy sensor heat pump, ERC

The measure requires installation of an HVAC occupancy sensing thermostat in the classroom. This control equipment includes, but is not limited to: An occupancy sensing thermostat, An occupancy sensor (wired or wireless), Wiring (if wired), Signal receiver and power pack (if wireless). The measure is only applicable for classrooms in education primary schools (EPr), and education secondary schools (ESe). This measure is not applicable for education community colleges, and education universities, unless these buildings have relocatable classrooms with packaged HVAC units. This measure is applicable to all vintages.



# Residential Measures

## Residential High Efficiency Furnace with Variable Speed Motor

AHRI List (web link): [Residential Furnaces](#)

Building Type
Single Family
Multi-Family
Mobile Home

	AFUE (%)
Tier 1	≥ 92.0 & < 95.0
Tier 2	≥ 95.0 & < 97.0
Tier 3	≥ 97.0

### Additional Eligibility Requirements based on AHRI Certified Product List:

Input Rating	≤ 225 Mbtuh	
Electronically Commutated Motor	Yes	
Furnace Type	Weatherized; Non-weatherized	
Fuel Type	Natural Gas; Natural Gas, Propane Gas*	

\*All equipment must be for use with Natural Gas ONLY. One incentive per household.

## Residential Gravity Wall Furnace

AHRI List (web link): [Direct Heating Equipment](#)

Residential Building Type
Single Family
Multi-Family

	Heating Type	AFUE (%)
Input Rating (Btu/h) ≥ 25,000 & < 35,000		
	Gravity	≥ 70.0
Input Rating (Btu/h) ≥ 35,000 & < 60,000		
	Gravity	≥ 70.0
Input Rating (Btu/h) ≥ 25,000 & < 42,000		
	Fan	≥ 82.0

\*Not eligible for New Construction

\*One measure per residential address/household

### Additional Eligibility Requirements based on AHRI Certified Product List:

Fuel Type	Natural Gas; Natural Gas, Propane Gas
Equipment Type	Wall Furnace

### Measures Covered by above Measure:

Gravity wall furnace residential 25000 Btuh 70 AFUE 2022
Gravity wall furnace residential 35000 Btuh 70 AFUE 2022
Gravity wall furnace residential 50000 Btuh 70 AFUE 2022
Fan wall furnace residential 30000 Btuh 82 AFUE 2022

# Residential Heat Pump HVAC, Fuel Substitution

AHRI List (web link): [Heat Pumps and Heat Pump Coils](#)

Residential Building Type
Single Family
Multi-Family
Mobile Home

Split Systems: SEER Rated Equipment			
	SEER		HSPF
Tier 1, SEER	≥16	AND	≥9
Tier 2, SEER	≥17	AND	≥9.4
Tier 3, SEER	≥18	AND	≥9.5
Tier 4, SEER	≥19	AND	≥9.5

Split Systems: SEER Rated Equipment			
	SEER2		HSPF2
Tier 1, SEER2	≥15.2	AND	≥7.7
Tier 2, SEER2	≥16	AND	≥8.0
Tier 3, SEER2	≥16.9	AND	≥8.1
Tier 4, SEER2	≥17.8	AND	≥8.1

Additional Qualifications for this measure:

- \*BOTH minimum SEER and HSPF need to be met to qualify
- \*Not eligible for New Construction
- \*Customer must receive Gas or Electric service from an IOU
- \*If equipment is both SEER and SEER2 rated, program eligibility will default to the SEER2 rating

Please note: Any incentive amounts or product types included in this and other supporting documents are intended as references only and are not meant to replace the PPC. The PPC will always have the most current incentive amount and qualifying products. Incentive levels can and will change throughout the life of the program based upon market trends, program performance, or utility needs and priorities. Please contact the program if you are uncertain of a product's eligibility or incentive level. You can contact the program by reaching out to your Account Manager, by emailing [info@comfortablyca.com](mailto:info@comfortablyca.com), or by calling 855-700-4651.